

DuraLife-brand cables are 2-hour certified under the UL 2196 standard for fire-resistive cables, meet the mandatory NFPA 72: National Fire Alarm and Signaling Code pathway survivability circuit requirements, and are commonly found in fire alarm circuit integrity (NEC Article 760), emergency systems (NEC Articles 700 & 708) and health care facilities (NEC Article 517) applications in high-rises, hospitals, bridges, tunnels and transit, and other critical facilities.

SELECTION GUIDE

	DuraLife® FPL-CIC	DuraLife® II FPLR Dual-Rated CI/CIC	DuraLife® FPLP-CI
Installation Method	In conduit per FHIT 28 A & B	In conduit per FHIT 28C or Free Air per NEC 760.24	NEC Article 760.24
2 Hour Fire Rating	UL 2196 Certified	UL 2196 Certified	UL 2196 Certified
Voltage Rating	300 Volts	300 Volts	300 Volts
Installation Usage	Ducts or Plenums, Risers or General Purpose (in conduit)	Ducts or Plenums, Risers or General Purpose (in conduit)	Plenums, Risers, or General Purpose (without conduit)
Constructions	18 AWG to 12 AWG Shielded and Unshielded	18 AWG to 12 AWG Shielded and Unshielded	18 AWG to 12 AWG Unshielded
Plenum	With Conduit	With Conduit	NFPA 262
2 Hour Rated Splice	Horizontal and Vertical	Horizontal and Vertical	Horizontal
Twists per Foot	3	3	3
Standard Lengths	1000 & 5000 ft.	1000 & 5000 ft.	1000 & 5000 ft.

