

DuraLife® II Dual Rated CI/CI Free Air

UL 2196 2-Hour Fire Resistive Cable

FPLR Shielded / Unshielded 105°C/300V

SPECIFICATIONS

Certified to the harsh requirements of the UL2196 Test for Fire Resistive Cables, the DuraLife II Dual Rated CI /CI cables ensure two-hour operation of critical systems in the event of a fire. The dual rating design offers the most versatility in meeting code survivability requirements in both in-conduit and free air installation scenarios.

Description: Dual Rated CI/CIC Cable. UL/CAN (ULC) 2196 Certified/UL 1424 Listed. FHIT/FHIT7 (ULC) System No. 28C. Low smoke, zero halogen design (LSZH).

Sizes Available: 2 conductor, 18-12 AWG unshielded; 18-14 AWG shielded.



CONSTRUCTION:

- **Conductor:** Oxygen-free bare copper (OFHC), solid and/or stranded
- **Insulation:** Proprietary ceramifiable silicone rubber
- **Assembly:** Color-coded black/red leads, 3 twists/foot
- **Jacket:** Red low smoke/zero halogen FRPE (black jacket available/special order)

APPLICATIONS:

- Hospitals & Healthcare Facilities
- High Rise & Mix use buildings
- Universities & College Campuses
- Stadiums, Casinos, places of assembly
- Transit bridges, tunnels and subways
- Government Facilities

CRITICAL SYSTEMS:

- Fire Alarm and EVAC Systems
- Smoke evacuation and control
- Fan & Pressurization systems
- Strobes & notification appliances
- Area of Refuge Systems
- Emergency lighting

COMPLIANCE & PERFORMANCE FEATURES:

- UL 1424 Listed FPLR/FPLR-CI (dual-rated) for Power-Limited Fire Alarm Circuits. Riser Rated. 300V/105°C classified.
- UL/CAN (ULC) Certified to UL 2196 2-hour fire rating in FHIT/FHIT7 28C
- CSA Certified FAS90; CSA Std. C22.2 No. 208-14 FT4-ST1
- UL Certified 2-hour fire rating as FPLR-CI for Free Air installed per NEC code
- UL 444 Listed "CMR/CMR-CI" as Communications Cable
- Fire alarm circuit integrity, emergency systems, and healthcare facilities (NEC Articles 760, 700 & 517)
- Meets National Fire Protection Code (NFPA 70 & 72) fire alarm survivability circuit requirements
- Meets National Fire Protection Code (NFPA 130 & 502) fire alarm survivability circuit requirements
- Compliance tested to UL 1424 as suitable for use in applications requiring wet rating
- Tested for Sunlight Resistance in compliance with UL 2556 requirements
- Suitable for 2-hour certified fire-resistive applications in EMT, IMC, or Phenolic conduit systems
- UL Listed File No. E-241484. UL Fire Directory R-21213.
- Splice Allowance



Scan here to access
DuraLife documents
on the go!

COPYRIGHT

This document is protected under copyright law and is the property of Radix Wire and Cable. Data contained herein is confidential to Radix Wire and Cable and this document and/or any part of the data contained herein may not be copied, duplicated or released for manufacturing or sale of equipment outside of Radix Wire and Cable or any affiliates without the prior written authorization of Radix Wire & Cable.

SPECIFICATIONS

DuraLife® II Dual Rated CIC/CI Free Air UL 2196 2-Hour Fire Resistant Cable FPLR Shielded/Unshielded 105°C/300V

HARDWARE & ACCESSORIES CERTIFIED: (Refer to DuraLife® II Installation Instructions/Phenolic Addendum for details)

- **EMT/IMC Conduit:** Wheatland/Western Tube
- **EMT/IMC Conduit:** Allied/Columbia (EMT: E-Z Pull Brand)
- **Phenolic Conduit:** Champion Fiberglass
- **EMT/IMC Compression Couplings:** Hubbell/Raco
- **EMT/IMC Compression Coupling:** Hubbell/Raco
- **NEMA 1 Splice Enclosure/Pull Box:** Eaton/Cooper (system use only)
- Standard UL listed steel 4/S Utility Box (CI only)
- **Expansion Couplers:** Bridgeport fittings (EMT/IMC)
- **Box Fittings:** Compression - Cooper Crouse-Hinds (EMT); Hubbell/Raco (EMT/IMC) Set Screw - Hubbell/Raco (EMT/IMC)
- **Conduit Clamps:** Erico (Phenolic conduit only)
- **Splice Connector:** 3M Butt-Type Crimp Terminals
- **Splice Tapes - 1":** 3M Silicone; St. Gobain Fiberglass Tape
- **Pulling Lubricant:** Polywater LZ

NON-SHIELDED: RADIX WIRE-II DURALIFE-II™ E241484 2/C #AWG FPLR/FPLR-CI/CMR 300V/105C / (UL) 2196 (ULC) 2-HR FIRE RESISTIVE CABLE FOR USE IN FHIT/FHIT7 ELECTRIC CIRCUIT INTEGRITY SYSTEM #28C. SEE UL FIRE RESISTANCE DIRECTORY R21213 // CSA LL13427 FAS90 300V FT4-ST1 Sun Res Wet (MONTH/YEAR) CI - NYC certified fire alarm cable (XXXX FT)

RADIX P/N	#COND	AWG	SOLID OR STRANDED	NOMINAL O.D. (INCH)	NET WEIGHT (LBS PER MFT)	RESISTANCE (OHMS/MFT)	NOMINAL CAPACITANCE (pF/FT)
CTU18A0102	2	18	Solid	.305	53	6.48	14.4
CTU16A0102	2	16	Solid	.335	62	3.99	15.3
CTU14A0102	2	14	Solid	.344	77	2.57	17.1
CTU14A0702	2	14	Stranded	.350	77	2.60	17.3
CTU12A0702	2	12	Stranded	.392	98	1.64	17.6

SHIELDED: RADIX WIRE-II DURALIFE-II™ E241484 2/C #AWG FPLR/FPLR-CI/CMR/SHLD 300V/105C / (UL) 2196 (ULC) 2-HR FIRE RESISTIVE CABLE FOR USE IN FHIT/FHIT7 ELECTRIC CIRCUIT INTEGRITY SYSTEM #28C. SEE UL FIRE RESISTANCE DIRECTORY R21213 // CSA LL13427 FAS90 300V FT4-ST1 Sun Res Wet (MONTH/YEAR) CI - NYC certified fire alarm cable (XXXX FT)

RADIX P/N	#COND	AWG	SOLID OR STRANDED	NOMINAL O.D. (INCH)	NET WEIGHT (LBS PER MFT)	RESISTANCE (OHMS/MFT)	NOMINAL CAPACITANCE (pF/FT)
CTS18A0102	2	18	Solid	.335	55	6.48	18.4
CTS16A0102	2	16	Solid	.360	65	3.99	19.1
CTS14A0102	2	14	Solid	.390	79	2.57	21.4
CTS14A0702	2	14	Stranded	.393	79	2.60	21.7

*Min-Max Spec Range ± .020

System Fill Allowances (EMT - 1/2" to 2"; IMC - 3/4" to 2")

EMT/IMC	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
Part No.	No. of Cables Max Fill					
CTU18A0102	1	2	4	6	10	N/A
CTU16A0102	1	1	3	5	7	10
CTU14A0102	1	1	3	5	7	10
CTU12A0102	1	1	2	4	5	10V/9H
CTS18A0102	1	1	3	5	8	N/A
CTS16A0102	1	1	3	5	7	10
CTS14A0102	N/A	1	2	4	6	10

System Fill Allowances (Phenolic Conduit - 1" to 2")

PHENOLIC	1"	1 1/4"	1 1/2"	2"
Part No.				
CTU18A0102	3	6	9	N/A
CTU16A0102	2	4	6	10
CTU14A0102	3	5	7	10
CTU12A0102	2	4	5	10V/9H
CTS18A0102	3	5	7	N/A
CTS16A0102	2	4	6	10
CTS14A0102	2	4	6	10



Radix Wire & Cable
26000 Lakeland Boulevard, Euclid, OH 44132
Tel: 216 731-9191 • Fax: 216 731-7082
www.radix-wire.com