

SPECIFICATIONS

DuraLife® Dual-Rated CIC/CI Cables

Certified to the harsh requirements of the UL2196 Test for Fire Resistive Cables, the DuraLife Dual-Rated CIC/CI cables ensure two-hour operation of critical systems in the event of a fire. The dual rating design offers the most versatility in meeting code survivability requirements in both in-conduit and free air installation scenarios.

Description: Dual-Rated CIC/CI Cable. UL/CAN (ULC) 2196 Certified/UL 1424 Listed. FHIT/FHIT7 (ULC) System No. 28C. Low smoke, zero halogen design (LSZH).

Sizes Available: 2 conductor, 18-12 AWG unshielded; 18-14 AWG shielded.

CONSTRUCTION:

- **Conductor:** Oxygen-free bare copper (OFHC), solid and/or stranded
- **Insulation:** Proprietary ceramifiable silicone rubber
- **Assembly:** Color-coded black/red leads, 3 twists/foot
- **Jacket:** Red low smoke/zero halogen FRPE with sequential footage markers (custom colors available/special order mins apply)

APPLICATIONS:

- Hospitals & Healthcare Facilities
- High Rise & Mix use buildings
- Universities & College Campuses
- Stadiums, Casinos, places of assembly
- Transit bridges, tunnels and subways
- Government Facilities

CRITICAL SYSTEMS:

- Fire Alarm and EVAC Systems
- Smoke evacuation and control
- Fan & Pressurization systems
- Strobes & notification appliances
- Area of Refuge Systems
- Emergency lighting

- UL 1424 Listed FPLR/FPLR-CI (dual-rated) for Power-Limited Fire Alarm Circuits. Riser Rated. 300V/105°C classified.
- UL/CAN (ULC formerly S-139) Certified to UL 2196 2-hour fire rating in FHIT/FHIT7 28C
- CSA Certified FAS90; CSA Std. C22.2 No. 208-14 FT4-ST1
- UL Certified 2-hour fire rating as FPLR-CI for Free Air installed per NEC code
- UL 444 Listed "CMR/CMR-CI" as Communications Cable
- Fire alarm circuit integrity, emergency systems, and healthcare facilities (NEC Articles 760, 700 & 517)
- Meets National Fire Protection Code (NFPA 70 & 72) fire alarm survivability circuit requirements
- Meets National Fire Protection Code (NFPA 130 & 502) fire alarm survivability circuit requirements
- Compliance tested to UL 1424 as suitable for use in applications requiring wet rating
- Meets UL1685 and FT4/IEEE 1202 requirements
- Tested for Sunlight Resistance in compliance with UL 2556 requirements
- Suitable for 2-hour certified fire-resistive applications in EMT, IMC, or Phenolic conduit systems
- UL Listed File No. E-241484. UL Fire Directory R-21213.
- Splice Allowance
- Performance testing of cables, cold bend test of complete cable per defined testing parameters and UL 1424
- NYC certified and CAFM approved

COPYRIGHT

This document is protected under copyright law and is the property of Radix Wire and Cable. Data contained herein is confidential to Radix Wire and Cable and this document and/or any part of the data contained herein may not be copied, duplicated or released for manufacturing or sale of equipment outside of Radix Wire and Cable or any affiliates without the prior written authorization of Radix Wire & Cable.

8-26-2025



DURALIFE®



Survivable Cable Solutions

SPECIFICATIONS

DuraLife® Dual-Rated CIC/CI Cables

HARDWARE & ACCESSORIES CERTIFIED: (Refer to DuraLife® II Installation Instructions/Phenolic Addendum for details)

- EMT/IMC Conduit: Wheatland/Western Tube
- EMT/IMC Conduit: Allied/Columbia (EMT: E-Z Pull Brand)
- Phenolic Conduit: Champion Fiberglass
- EMT/IMC Compression Couplings: Hubbell/Raco
- EMT/IMC Set-Screw Coupling: Hubbell/Raco
- Phenolic Coupling: Champion Fiberglass
- NEMA 1 Splice Enclosure/Pull Box: Eaton/Cooper (system use only)
- Standard UL listed steel 4/S Utility Box (CI only)
- Expansion Couplers: Bridgeport fittings (EMT/IMC)
- Box Fittings: Compression - Cooper Crouse-Hinds (EMT); Hubbell/Raco (EMT/IMC)
Set Screw - Hubbell/Raco (EMT/IMC)
Phenolic - Champion Fiberglass
- Conduit Clamps: Erico (Phenolic conduit only)
- Splice Connector: 3M Butt-Type Crimp Terminals
- Splice Tapes - 1": 3M Silicone; St. Gobain Fiberglass Tape
- Pulling Lubricant: Polywater LZ

UNSHIELDED:

RADIX P/N	#COND	AWG	SOLID OR STRANDED	NOMINAL O.D. (INCH)	NET WEIGHT (LBS PER MFT)	RESISTANCE (OHMS/MFT)	NOMINAL CAPACITANCE (pF/FT)
CTU18A0102	2	18	Solid	.305	53	6.48	14.4
CTU16A0102	2	16	Solid	.335	62	3.99	15.3
CTU16A0702	2	16	Stranded	.335	62	4.02	15.6
CTU14A0102	2	14	Solid	.344	77	2.57	17.1
CTU14A0702	2	14	Stranded	.350	77	2.60	17.3
CTU12A0102	2	12	Solid	.392	98	1.61	17.4
CTU12A0702	2	12	Stranded	.392	98	1.64	17.6

SHIELDED:

RADIX P/N	#COND	AWG	SOLID OR STRANDED	NOMINAL O.D. (INCH)	NET WEIGHT (LBS PER MFT)	RESISTANCE (OHMS/MFT)	NOMINAL CAPACITANCE (pF/FT)
CTS18A0102	2	18	Solid	.335	55	6.48	18.4
CTS16A0102	2	16	Solid	.360	65	3.99	19.1
CTS16A0702	2	16	Stranded	.360	65	4.02	19.4
CTS14A0102	2	14	Solid	.390	79	2.57	21.4
CTS14A0702	2	14	Stranded	.393	79	2.60	21.7

*Min-Max Spec Range ± .020

System Fill Allowances (EMT - 1/2" to 2"; IMC - 3/4" to 2")

EMT/IMC	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
Part No.	No. of Cables Max Fill					
CTU18A0102	1	2	4	6	10	N/A
CTU16A0102*	1	1	3	5	7	10
CTU14A0102*	1	1	3	5	7	10
CTU12A0102*	1	1	2	4	5	10V/9H
CTS18A0102	1	1	3	5	8	N/A
CTS16A0102*	1	1	3	5	7	10
CTS14A0102*	N/A	1	2	4	6	10

*System fill allowances same for stranded version.

System Fill Allowances (Phenolic Conduit - 1" to 2")

PHENOLIC	1"	1 1/4"	1 1/2"	2"
Part No.	No. of Cables Max Fill			
CTU18A0102	3	6	9	N/A
CTU16A0102*	2	4	6	10
CTU14A0102*	3	5	7	10
CTU12A0102*	2	4	5	10V/9H
CTS18A0102	3	5	7	N/A
CTS16A0102*	2	4	6	10
CTS14A0102*	2	4	6	10

*System fill allowances same for stranded version.



www.radix-wire.com